

Fire Application #248348 - Gymnastics Connections

[illegible]



Fire Application #248348 - Gymnastics Connections

Project Contact

Company Name: Western States Fire Protection

Name: Jim Stewart

Email: jim.stewart@wsfp.us

Address: 14690 NE 95th Street Unit 101
Redmond WA 98052

Phone #: (425) 881-0100

Project Type

Nonresidential

Activity Type

Alteration

Scope of Work

Fire Sprinkler Systems

Project Name: Gymnastics Connections

Description of Work: Add 3 fire sprinklers below new stair.

Project Details

System Information

This is a modification or addition to an existing system

Fire System Type

NFPA 13

Alterations

There are alterations to devices or systems.

Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

Quick Response or Recalled Head Relocation

No heads are being relocated.

Change of Use

This is not a change of use.

Hydraulic Calculations

There is no change to the hydraulic calculations.

Hazard Classification

The space is classified as Light/Ordinary Hazard.

Mains and Cross Mains

Mains or cross mains are not being relocated.

Heads - Excluding Quick Response and Recalled

1 - 25 total heads

Fire System Counts

Number of Heads Added 3

Number of Total Heads 3